

बिड दस्तावेज़ / Bid Document

बिड विवरण / Bid Details	
बिड बंद होने की तारीख/समय / Bid End Date/Time	30-07-2026 20:00:00
बिड खुलने की तारीख/समय / Bid Opening Date/Time	30-07-2026 20:30:00
बिड पेशकश वैधता (बंद होने की तारीख से) / Bid Offer Validity (From End Date)	150 (Days)
मंत्रालय/राज्य का नाम / Ministry/State Name	Ministry Of Health And Family Welfare
विभाग का नाम / Department Name	Department Of Health And Family Welfare
संगठन का नाम / Organisation Name	Central Medical Services Society (cmss)
कार्यालय का नाम / Office Name	Central Medical Services Society
शिकायत निवारण के संपर्क विवरण / Contact details of Grievance redressal	HOD Email id : manishbhaskar@cmss.gov.in Buyer Email id: agmproc6@cmss.gov.in
कुल मात्रा / Total Quantity	1356434
वस्तु श्रेणी / Item Category	Ice Lined Refrigerator (Q3) , Deep freezer (Q2) , Walk in Cooler (Q3) , Walk In Freezer WIFs 32 CuM , Walk In Freezer WIFs 20 CuM , Voltage Stabilizer Normal 150v to 280v , Voltage Stabilizer Low 110v to 280v , Vaccine Carriers , Ice Packs , Stem Alcohol Thermometer
GeMARPTS में खोजी गई स्ट्रिंग्स / Searched Strings used in GeMARPTS	Walk In Freezer (WIFs) - 32 CuM, Walk In Freezer (WIFs) - 20 CuM, Voltage Stabilizer (Normal) (150v-280v), Voltage Stabilizer (Low) (110v-280v), Vaccine Carriers (with 4 ice packs), Ice Packs (0.3ltr), Stem Alcohol Thermometer

बिड विवरण/Bid Details

Searched String: Walk In Freezer (WIFs) - 32 CuM

Walk in Cooler

Searched String: Walk In Freezer (WIFs) - 20 CuM

Category not available on GeM for the text string uploaded by the buyer

Searched String: Voltage Stabilizer (Normal) (150v-280v)

Automatic Line Voltage Correctors (Step Type) For Domestic Use (Stabilizer) Conforming To IS 8448, V - Belts - Endless V - Belt for Industrial Purposes as per IS 2494, XLPE Cable for Working Voltage up to and Including 1.1 KV Marked To IS 7098 (Part 1), Insulation Tester, Non-Contact High Voltage Detector, Portable Fire Extinguishers (V3) ISI Marked to IS 15683, Small Angle Grinders, Cotton Towelling And Towels Conforming To IS 7056 (V4), cobweb brush, Digital pH Meter

Searched String: Voltage Stabilizer (Low) (110v-280v)

Automatic Line Voltage Correctors (Step Type) For Domestic Use (Stabilizer) Conforming To IS 8448, V - Belts - Endless V - Belt for Industrial Purposes as per IS 2494, Low Voltage Surge Protective Devices Connected to Low Voltage Power Systems Conforming To IS 16463 (Part 11), Plug In Relay For Heavy Coil Voltage 30V, 48V, 50V, 110V, 220V, and 250V DC (BHEL-SCR), Insulation Tester, Low Voltage MCCB with Thermal Magnetic/Electronic Trip Unit Conforming To IS/IEC 60947 (Part 2), Disconnectors (Isolators) for Working Voltage Up to and Including 1 kV Conforming To IS/IEC 60947 (Part 3), Portable Fire Extinguishers (V3) ISI Marked to IS 15683, Air Circuit Breaker Conforming To IS/IEC 60947 (Part 2), AC Voltage Transducer (V2)

Searched String: Vaccine Carriers (with 4 ice packs)

Salicylic acid as per IS:7559, Ice Lined Refrigerator (V2), Aluminium Hydroxide as per IS:10896, Corrugated Fibreboard Cartons [for packing Soluble Coffee With 30% Chicory Powder (Polyester pouches) - DEFENCE], Nasal Pack (V2), Lumpy Skin Disease Veterinary Vaccine

Searched String: Ice Packs (0.3ltr)

ice packs, Electronic Weighing Scales, Line Interactive UPS with AVR (V2), Flat Cable, Copper Conductor with PVC Insulation and Sheathed ISI Marked To IS 694, Online UPS (V2), Endotracheal Tube - Sterile (Single Use), PVC Insulated Copper Cable Single Core and Multi Core Circular Sheathed with Rigid Conductor (V2) ISI Marked To IS 694, Galvanized Steel Chain Link Fence Fabric (V2) conforming to IS 2721, PVC Insulated Copper Cord Single Core and Multi Core Circular Sheathed with Flexible Conductor (V2) ISI Marked To IS 694, Plastic Ice Box (V2)

Searched String: Stem Alcohol Thermometer

Clinical Thermometer - Solid Stem Type, Digital Medical Thermometer, Candy Thermometer / Food Thermometer, Room Thermometer, Handheld Digital Infrared Thermometer, Octyl Alcohol, Turp Electrodes Cutting Loop / Collins Knife / Bipolar and Monopolar, Benzyl alcohol,

GeMARPTS में खोजा गया परिणाम / Searched Result generated in GeMARPTS

बिड विवरण / Bid Details	
अधिसूचना के लिए चयनित प्रासंगिक श्रेणियाँ / Relevant Categories selected for notification	• Alcohol Based Hand Sanitizer, Alcohol Swab • Automatic Line Voltage Correctors (Step Type) For Domestic Use (Stabilizer) Conforming To IS 8448 • Plastic Ice Box (V2) • Walk in Cooler
बीओक्यू शीर्षक / BOQ Title	Procurement of Cold Chain Equipment for UIP
बिडर का न्यूनतम औसत वार्षिक टर्नओवर (3 वर्षों का) / Minimum Average Annual Turnover of the bidder (For 3 Years)	20 Lakh (s)
मूल उपकरण निर्माता का औसत टर्नओवर (गत 3 वर्षों का) / OEM Average Turnover (Last 3 Years)	20 Lakh (s)
उन्हीं/समान सेवा के लिए अपेक्षित विगत अनुभव के वर्ष / Years of Past Experience Required for same/similar service	2 Year (s)
टर्नओवर के लिए एमएसई को छूट प्राप्त है / MSE Relaxation for Turnover	Yes Partial Turn over value - 20 (in lakhs)
टर्नओवर के लिए स्टार्टअप को छूट प्राप्त है / Startup Relaxation for Turnover	Yes Partial Turn over value - 20 (in lakhs)
विक्रेता से मांगे गए दस्तावेज़ / Document required from seller	Experience Criteria, Past Performance, Bidder Turnover, Certificate (Requested in ATC), OEM Annual Turnover, Additional Doc 1 (Requested in ATC), Additional Doc 2 (Requested in ATC), Additional Doc 3 (Requested in ATC) *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
क्या आप निविदाकारों द्वारा अपलोड किए गए दस्तावेजों को निविदा में भाग लेने वाले सभी निविदाकारों को दिखाना चाहते हैं? संदर्भ मेनू है / Do you want to show documents uploaded by bidders to all bidders participated in bid?	Yes (Documents submitted as part of a clarification or representation during the tender/bid process will also be displayed to other participated bidders after log in)
बिड लगाने की समय सीमा स्वतः नहीं बढ़ाने के लिए आवश्यक बिड की संख्या। / Minimum number of bids required to disable automatic bid extension	1
दिनों की संख्या, जिनके लिए बिड लगाने की समय-सीमा बढ़ाई जाएगी। / Number of days for which Bid would be auto-extended	3
ऑटो एक्सटेंशन अधिकतम कितनी बार किया जाना है। / Number of Auto Extension count	1
विगत प्रदर्शन / Past Performance	40 %
बिड से रिवर्स नीलामी सक्रिय किया / Bid to RA enabled	No
बिड का प्रकार / Type of Bid	Two Packet Bid
प्राथमिक उत्पाद श्रेणी / Primary product category	Ice Lined Refrigerator

बिड विवरण/Bid Details	
तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय /Time allowed for Technical Clarifications during technical evaluation	2 Days
निरीक्षण आवश्यक (सूचीबद्ध निरीक्षण प्राधिकरण /जेम के साथ पूर्व पंजीकृत एजेंसियों द्वारा)/Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
मूल्यांकन पद्धति/Evaluation Method	Item wise evaluation
मध्यस्थता खंड/Arbitration Clause	No
सुलह खंड/Mediation Clause	No

ईएमडी विवरण/EMD Detail

एडवाइजरी बैंक/Advisory Bank	HDFC Bank
Schedule 1 ईएमडी राशि/EMD Amount (In INR)	983753
Schedule 2 ईएमडी राशि/EMD Amount (In INR)	2861600
Schedule 3 ईएमडी राशि/EMD Amount (In INR)	969960
Schedule 4 ईएमडी राशि/EMD Amount (In INR)	2540160
Schedule 5 ईएमडी राशि/EMD Amount (In INR)	295540
Schedule 6 ईएमडी राशि/EMD Amount (In INR)	101400
Schedule 7 ईएमडी राशि/EMD Amount (In INR)	130650
Schedule 8 ईएमडी राशि/EMD Amount (In INR)	100000
Schedule 9 ईएमडी राशि/EMD Amount (In INR)	377790
Schedule 10 ईएमडी राशि/EMD Amount (In INR)	570183
Schedule 11 ईएमडी राशि/EMD Amount (In INR)	228106
Schedule 12 ईएमडी राशि/EMD Amount (In INR)	1458226
Schedule 13 ईएमडी राशि/EMD Amount (In INR)	139609
Schedule 14 ईएमडी राशि/EMD Amount (In INR)	116581

ईपीबीजी विवरण /ePBG Detail

आवश्यकता/Required	No
-------------------	----

(a). जेम की शर्तों के अनुसार ईएमडी छूट के इच्छुक बिडर को संबंधित कैटेगरी के लिए बिड के साथ वैध समर्थित दस्तावेज प्रस्तुत करने है। एमएसई

केटेगरी के अंतर्गत केवल वस्तुओं के लिए विनिर्माता तथा सेवाओं के लिए सेवा प्रदाता ईएमडी से छूट के पात्र हैं। व्यापारियों को इस नीति के दायरे से बाहर रखा गया है।/EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy.

(b). The EMD Amount will be applicable for each schedule/group selected during Bid creation.

(c).ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए। / EMD & Performance security should be in favour of Beneficiary, wherever it is applicable.

(d).ईएमडी और संपादन जमानत राशि लाभार्थी के पक्ष में होनी चाहिए। / Earnest Money Deposit (EMD) shall also be accepted by the buyer in the form of a surety bond.

लाभार्थी /Beneficiary :

DG AND CEO

Central Medical Services Society, Department of Health and Family Welfare, Central Medical Services Society (CMSS), Ministry of Health and Family Welfare
(Cmss)

विभाजन/Splitting

विभाजन/Splitting Applied	Yes
बोलीदाताओं की अधिकतम संख्या, जिनके बीच ऑर्डर विभाजित किया जा सकता है। / Maximum No. Of Bidders Amongst Which Order May Be Split	2
विभाजन मानदंड इस बात पर आधारित है कि कौन सी क्वांटिटी को वितरित किया जाएगा / Split Criteria based on which quantity will be distributed	70:30

एमआईआई खरीद वरीयता / MII Purchase Preference

एमआईआई खरीद वरीयता / MII Purchase Preference	Yes
मेक इन इंडिया विक्रेताओं को खरीद में प्राथमिकता, यदि उनका मूल्य $L1+X\%$ तक की सीमा में है / Purchase Preference to MII sellers available upto price within $L1+X\%$	20
मेक इन इंडिया खरीद में प्राथमिकता के लिए बिड की मात्रा का अधिकतम प्रतिशत / Maximum Percentage of Bid quantity for MII purchase preference	50

सार्वजनिक खरीद (मेक-इन-इंडिया को प्राथमिकता) आदेश 2017 के अनुसार केवल क्लास 1/क्लास 2 के स्थानीय आपूर्तिकर्ताओं को ही भागीदारी की अनुमति है दिनांक 16.09.2020 (समय-समय पर संशोधित एवं लागू) / Allow participation only from Class 1/Class 2 local suppliers as per the Public procurement(Preference to Make-in-india) order 2017 date 16.09.2020(as amended and applicable time to time)	Yes, in compliance with the MII ORDER : DPIIT Order(as amended and applicable time to time)
---	---

एमएसई खरीद वरीयता/MSE Purchase Preference

एमएसई खरीद वरीयता/MSE Purchase Preference	Yes
सूक्ष्म और लघु उद्यम मूल उपकरण निर्माताओं/सेवा प्रदाता को खरीद में प्राथमिकता, यदि उनका मूल्य $L1+X\%$ / Purchase Preference to MSE OEMs/ Service Provider available upto price within $L1+X\%$	15
सूक्ष्म और लघु उद्यम मूल उपकरण निर्माता/सेवा प्रदाता को खरीद में प्राथमिकता के लिए बिड की मात्रा का अधिकतम प्रतिशत / Percentage of Bid quantity/amount for MSE OEMs/ Service Provider Purchase preference	25

1. If the bidder is a Micro or Small Enterprise (MSE) as per latest orders issued by Ministry of MSME, the bidder shall be relaxed from the eligibility criteria of "Bidder Turnover" as defined above subject to meeting of quality and technical specifications. If the bidder itself is MSE OEM of the offered products, it would be relaxed from the "OEM Average Turnover" criteria also subject to meeting of quality and technical specifications. The bidder seeking Relaxation from Turnover, shall upload the supporting documents to prove his eligibility for Relaxation.
2. If the bidder is a DPIIT registered Startup, the bidder shall be relaxed from the the eligibility criteria of "Bidder Turnover" as defined above subject to their meeting of quality and technical specifications. If the bidder is DPIIT Registered OEM of the offered products, it would be relaxed from the "OEM Average Turnover" criteria also subject to meeting of quality and technical specifications. The bidder seeking Relaxation from Turnover shall upload the supporting documents to prove his eligibility for Relaxation.
3. The minimum average annual financial turnover of the bidder during the last three years, ending on 31st March of the previous financial year, should be as indicated above in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the bidder is less than 3-year-old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.
4. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM of the product offered in the bid {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU for number of Financial years as indicated above in the bid document before the bid opening date. Copies of relevant contracts and delivery acceptance certificates like CRAC to be submitted along with bid in support of having supplied some quantity during each of the Financial year. In case of bunch bids, the category of primary product having highest value should meet this criterion.
5. OEM Turn Over Criteria: The minimum average annual financial turnover of the OEM of the offered product during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the OEM is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.
6. Preference to Make In India products (For bids < 200 Crore):Preference shall be given to Class 1 local supplier as defined in public procurement (Preference to Make in India), Order 2017 as amended from time to time and its

subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products. The minimum local content to qualify as a Class 1 local supplier is denoted in the bid document. If the bidder wants to avail the Purchase preference, the bidder must upload a certificate from the OEM regarding the percentage of the local content and the details of locations at which the local value addition is made along with their bid, failing which no purchase preference shall be granted. In case the bid value is more than Rs 10 Crore, the declaration relating to percentage of local content shall be certified by the statutory auditor or cost auditor, if the OEM is a company and by a practicing cost accountant or a chartered accountant for OEMs other than companies as per the Public Procurement (preference to Make-in -India) order 2017 dated 04.06.2020. Only Class-I and Class-II Local suppliers as per MII order dated 4.6.2020 will be eligible to bid. Non - Local suppliers as per MII order dated 04.06.2020 are not eligible to participate. However, eligible micro and small enterprises will be allowed to participate .The buyers are advised to refer the OM No.F.1/4/2021-PPD dated 18.05.2023.

[OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017 and its subsequent Orders/Notifications issued by concerned Ministry .Benefits of MSE will be allowed only if seller/service provider is validated on-line in GeM profile as well as validated and approved by Buyer after evaluation of documents submitted.

7. Purchase preference to Micro and Small Enterprises (MSEs): Purchase preference will be given to MSEs having valid Udyam Certificate and whose credentials are validated online through Udyam Registration portal as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail themselves of the Purchase preference, the bidder must be the manufacturer / OEM of the offered product on GeM. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises and hence resellers offering products manufactured by some other OEM are not eligible for any purchase preference. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service, and Buyer will decide eligibility for purchase preference based on documentary evidence submitted in case of product bids, whereas in case of services the eligibility is automatically validated. If L-1 is not an MSE and MSE Seller (s) has / have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such MSE Seller shall be given opportunity to match L-1 price and contract will be awarded for 25% (selected by Buyer) percentage of total quantity. The buyers are advised to refer the [OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017. Benefits of MSE will be allowed only if seller is validated on-line in GeM profile as well as validated and approved by Buyer after evaluation of documents submitted.

8. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

9. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 40% of bid quantity, in at least one of the last three Financial years before the bid opening date to any Central / State Govt Organization / PSU. Copies of relevant contracts (proving supply of cumulative order quantity in any one financial year) to be submitted along with bid in support of quantity supplied in the relevant Financial year. In case of bunch bids, the category related to primary product having highest bid value should meet this criterion.

Pre Bid Detail(s)

मूल्य भिन्नता खंड दस्तावेज़/Pre-Bid Date and Time	प्री-बिड स्थान/Pre-Bid Venue
14-07-2026 11:00:00	CMSS HQ, New Delhi

मूल्यांकन विधि(मदवार मूल्यांकन विधि) / Evaluation Method (Item Wise Evaluation Method)

Contract will be awarded schedule wise and the determination of L1 will be done separately for each schedule. The details of item-consignee combination covered under each schedule are as under:

मूल्यांकन अनुसूचियां / Evaluation Schedules	वस्तु/श्रेणी / Item/Category	मात्रा / Quantity
---	------------------------------	-------------------

Schedule 1	Ice Lined Refrigerator	1046
Schedule 2	Ice Lined Refrigerator	3577
Schedule 3	Deep Freezer	1370
Schedule 4	Deep Freezer	4536
Schedule 5	Walk In Cooler	14
Schedule 6	Walk In Cooler	6
Schedule 7	Walk In Cooler	15
Schedule 8	Walk In Freezer Wifs 32 Cum	5
Schedule 9	Walk In Freezer Wifs 20 Cum	21
Schedule 10	Voltage Stabilizer Normal 150v To 280v	28958
Schedule 11	Voltage Stabilizer Low 110v To 280v	10062
Schedule 12	Vaccine Carriers	340707
Schedule 13	Ice Packs	873105
Schedule 14	Stem Alcohol Thermometer	93012

Ice Lined Refrigerator (1046 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 25% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Construction	Material of Construction of body	Galvanized Steel, Prepainted Galvanised Steel
	Net Vaccine Storage Capacity (minimum)	80, 130, 180, 250 Or higher (liter)
Warranty	Warranty	1, 2, 3, 4, 5 (year)

अतिरिक्त विशिष्टि दस्तावेज़ /Additional Specification Documents

Applicable Specification Document	View
-----------------------------------	----------------------

प्रेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Anurodh Singh	110021,Second Floor , Viswa Yuvak Kendra , Chanakyapuri New Delhi -110021	1046	15

Ice Lined Refrigerator (3577 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 25% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Construction	Material of Construction of body	Galvanized Steel, Prepainted Galvanised Steel
	Net Vaccine Storage Capacity (minimum)	80, 130, 180, 250 Or higher (liter)
Warranty	Warranty	1, 2, 3, 4, 5 (year)

अतिरिक्त विशिष्टि दस्तावेज़ /Additional Specification Documents

Applicable Specification Document	View
--------------------------------------	----------------------

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Anurodh Singh	110021,Second Floor , Viswa Yuvak Kendra , Chanakyapuri New Delhi -110021	3577	15

Deep Freezer (1370 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 25% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Standards	Conformity to Standards	CE (with 4 digit notified number), USFDA, BIS (As per medical directive)
Performance Parameters	Capacity in liters	250-300, 310-350, 360-400, 401-500, 501-600, 105 - 150, 155-195, 200-245, < 200, 301-500, 501-700, 701-900, 901-1100, 1101-1200, 200-250
	Type of cabinet	Chest, Horizontal, Vertical, Upright, Upright double door
	Castors	Heavy duty lockable, NA (if no castors provided)
	Number of corrosion resistant racks	2, 3, 4, 5, 6, 7, 8, 9, >10
	Number of inner storage compartments with insulated doors and	3, 4, 5, 1, 2
	Warranty of Freezer in Years (from the date of installation)	2, 3, 4, 5, 1
Additional Parameters	CO₂ cylinder should be supplied with freezer for backup	Yes, No
	Temperature Chart recorder to be provided	Yes, No

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Anurodh Singh	110021, Second Floor , Viswa Yuvak Kendra , Chanakyapuri New Delhi -110021	1370	15

Deep Freezer (4536 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 25% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
---------------------	-------------------------------------	---

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Standards	Conformity to Standards	CE (with 4 digit notified number), USFDA, BIS (As per medical directive)
Performance Parameters	Capacity in liters	250-300, 310-350, 360-400, 401-500, 501-600, 105 - 150, 155-195, 200-245, < 200, 301-500, 501-700, 701-900, 901-1100, 1101-1200, 200-250
	Type of cabinet	Chest, Horizontal, Vertical, Upright, Upright double door
	Castors	Heavy duty lockable, NA (if no castors provided)
	Number of corrosion resistant racks	2, 3, 4, 5, 6, 7, 8, 9, >10
	Number of inner storage compartments with insulated doors and	3, 4, 5, 1, 2
	Warranty of Freezer in Years (from the date of installation)	2, 3, 4, 5, 1
Additional Parameters	CO ₂ cylinder should be supplied with freezer for backup	Yes, No
	Temperature Chart recorder to be provided	Yes, No

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Anurodh Singh	110021, Second Floor , Viswa Yuvak Kendra , Chanakyapuri New Delhi -110021	4536	15

Walk In Cooler (14 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 25% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Technical parameters	Gross internal volume	16.5, 32, 40
Door	Door Type	Heavy duty lock - lockable with 100% fail-safe provision for opening from inside, The door should be self-closing type
Shelves	No of Shelves	Four shelves above the ground all around the wall and intermediate shelves should be placed suitably, The total area covered by shelves should be at least 42% of the ground area
Diesel generating set	AMF Control Panel components	Generator voltage/AC Mains voltage, Generator Current, Power Factor, Frequency, Energy, Three attempts engine start/engine cranking relay. On - delay timer for load change over, On-delay timer for engine shut of, Over current relay, Modeselectorswitchforsettingthepanelonanyoneposition such as off for auto or manual or test, Engine On-Off switch (Push button type), MCCB of suitable rating shall be provided, Rectangular aluminium bus bars (one number for each phase, neutral and Earthing terminal)of adequate ratings duly colour coded with heat shrinkable PVC sleeves, Two contactors of suitable rating (one for DG set & one for AC mains)withover load relay, Under-voltage relay for mains, Battery charger complete with voltage regulator, float or booster selector switch, on-off switch, voltmeter and ammeter for charging the battery from mains. (This will be in addition to the battery charging alternator fitted on the engine)
	Diesel Engine accessories	Fuel tank with capacity for 72 hours continuous running at full load, Engine instrument Panel consisting of starting switch with Key,Lube Oil temperature and pressure gauge, (water temperature gauge in case of water cooled engine),RPM indicator and hour meter, Safety control to shut down the engine in the event of flow lube oil pressure or high cylinder head temperature in case of air cooled engine or high water temperature in case of water cooled engines, Radiators in case of water-cooled engines, Exhaust silencer of Residential type, 12V starting system complete with starter motor, charging alternator and Cut-out, Lead Acid Battery or semi maintenance free battery of suitable ratings with connecting cables and the battery/ies shall conform to relevant IS Specification, Standard set of tools required for service and maintenance of the DG set shall be provided to the consignee along with each DG set
	Rated value , KVA	15

प्रेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	प्रेषित/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Anurodh Singh	110021,Second Floor , Viswa Yuvak Kendra , Chanakyapuri New Delhi -110021	14	15

Walk In Cooler (6 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 25% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Technical parameters	Gross internal volume	16.5, 32, 40
Door	Door Type	Heavy duty lock - lockable with 100% fail-safe provision for opening from inside, The door should be self-closing type
Shelves	No of Shelves	Four shelves above the ground all around the wall and intermediate shelves should be placed suitably, The total area covered by shelves should be at least 42% of the ground area
Diesel generating set	AMF Control Panel components	Generator voltage/AC Mains voltage, Generator Current, Power Factor, Frequency, Energy, Three attempts engine start/engine cranking relay. On - delay timer for load change over, On-delay timer for engine shut of, Over current relay, Modeselectorswitchforsettingthepanelonanyoneposition such as off for auto or manual or test, Engine On-Off switch (Push button type), MCCB of suitable rating shall be provided, Rectangular aluminium bus bars (one number for each phase, neutral and Earthing terminal)of adequate ratings duly colour coded with heat shrinkable PVC sleeves, Two contactors of suitable rating (one for DG set & one for AC mains)withover load relay, Under-voltage relay for mains, Battery charger complete with voltage regulator, float or booster selector switch, on-off switch, voltmeter and ammeter for charging the battery from mains. (This will be in addition to the battery charging alternator fitted on the engine)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Diesel Engine accessories	Fuel tank with capacity for 72 hours continuous running at full load, Engine instrument Panel consisting of starting switch with Key,Lube Oil temperature and pressure gauge, (water temperature gauge in case of water cooled engine),RPM indicator and hour meter, Safety control to shut down the engine in the event of flow lube oil pressure or high cylinder head temperature in case of air cooled engine or high water temperature in case of water cooled engines, Radiators in case of water-cooled engines, Exhaust silencer of Residential type, 12V starting system complete with starter motor, charging alternator and Cut-out, Lead Acid Battery or semi maintenance free battery of suitable ratings with connecting cables and the battery/ies shall conform to relevant IS Specification, Standard set of tools required for service and maintenance of the DG set shall be provided to the consignee along with each DG set
	Rated value , KVA	15

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Anurodh Singh	110021,Second Floor , Viswa Yuvak Kendra , Chanakyapuri New Delhi -110021	6	15

Walk In Cooler (15 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 25% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Technical parameters	Gross internal volume	16.5, 32, 40
Door	Door Type	Heavy duty lock - lockable with 100% fail-safe provision for opening from inside, The door should be self-closing type

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Shelves	No of Shelves	Four shelves above the ground all around the wall and intermediate shelves should be placed suitably, The total area covered by shelves should be at least 42% of the ground area
Diesel generating set	AMF Control Panel components	Generator voltage/AC Mains voltage, Generator Current, Power Factor, Frequency, Energy, Three attempts engine start/engine cranking relay. On - delay timer for load change over, On-delay timer for engine shut of, Over current relay, Modeselectorswitchforsettingthepanelonanyonepositionsuchasoffor auto or manual or test, Engine On-Off switch (Push button type), MCCB of suitable rating shall be provided, Rectangular aluminium bus bars (one number for each phase, neutral and Earthing terminal)of adequate ratings duly colour coded with heat shrinkable PVC sleeves, Two contactors of suitable rating (one for DG set & one for AC mains)withover load relay, Under-voltage relay for mains, Battery charger complete with voltage regulator, float or booster selector switch, on-off switch, voltmeter and ammeter for charging the battery from mains. (This will be in addition to the battery charging alternator fitted on the engine)
	Diesel Engine accessories	Fuel tank with capacity for 72 hours continuous running at full load, Engine instrument Panel consisting of starting switch with Key,Lube Oil temperature and pressure gauge, (water temperature gauge in case of water cooled engine),RPM indicator and hour meter, Safety control to shut down the engine in the event of flow lube oil pressure or high cylinder head temperature in case of air cooled engine or high water temperature in case of water cooled engines, Radiators in case of water-cooled engines, Exhaust silencer of Residential type, 12V starting system complete with starter motor, charging alternator and Cut-out, Lead Acid Battery or semi maintenance free battery of suitable ratings with connecting cables and the battery/ies shall conform to relevant IS Specification, Standard set of tools required for service and maintenance of the DG set shall be provided to the consignee along with each DG set
	Rated value , KVA	15

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
---------------	---	-------------	------------------	------------------------------

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Anurodh Singh	110021,Second Floor , Viswa Yuvak Kendra , Chanakyapuri New Delhi -110021	15	15

Walk In Freezer WIFs 32 CuM

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 25% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Anurodh Singh	110021,Second Floor , Viswa Yuvak Kendra , Chanakyapuri New Delhi -110021	5	90

Walk In Freezer WIFs 20 CuM

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 25% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परिषदी/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परिषदी/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Anurodh Singh	110021,Second Floor , Viswa Yuvak Kendra , Chanakyapuri New Delhi -110021	21	90

Voltage Stabilizer Normal 150v To 280v

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 25% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परिषदी/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परिषदी/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Anurodh Singh	110021,Second Floor , Viswa Yuvak Kendra , Chanakyapuri New Delhi -110021	28958	90

Voltage Stabilizer Low 110v To 280v

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 25% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Anurodh Singh	110021,Second Floor , Viswa Yuvak Kendra , Chanakyapuri New Delhi -110021	10062	90

Vaccine Carriers

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 25% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Anurodh Singh	110021,Second Floor , Viswa Yuvak Kendra , Chanakyapuri New Delhi -110021	340707	90

Ice Packs

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 25% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Anurodh Singh	110021,Second Floor , Viswa Yuvak Kendra , Chanakyapuri New Delhi -110021	873105	90

Stem Alcohol Thermometer

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 25% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Anurodh Singh	110021,Second Floor , Viswa Yuvak Kendra , Chanakyapuri New Delhi -110021	93012	90

क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें/Buyer Added Bid Specific Terms and Conditions**1. Buyer Added Bid Specific ATC**

Buyer uploaded ATC document [Click here to view the file.](#)

अस्वीकरण/Disclaimer

The Additional Terms and Conditions (ATC) have been incorporated by the Buyer after approval of their Competent Authority. The Buyer ,is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any restriction arising in the bidding process due to these ATCs

and including the modification of technical specifications and / or terms and conditions governing the bid. All representations / grievances pertaining to the ATC clauses shall be raised with the buyer organization directly and not with GeM. If any of the clause(s) is/are incorporated by the Buyer regarding the following, the bid & resultant contract shall be treated as null & void. Further, GeM reserves the right, at its sole discretion, to cancel the bid forthwith, without issuance of any prior notice or intimation :-

1. Publishing Custom / BOQ bids for items for which regular GeM categories are available (unless such Custom / BOQ item is bunched with the major regular product Category Item).
2. Mandating procurement of / from specific Brand / Make / Model / Manufacturer / Dealer except in case of Single Bid / Proprietary Article Certificate (PAC) Buying.
3. Inclusion of disqualification criteria related to suspension of seller / service provider, where such suspension period has already expired.
4. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
5. Publishing bids on GeM for procurement of works.
6. Procurement of Goods by creating a Service bid on GeM & vice-versa.
7. Seeking sample with bid or approval of samples during bid evaluation process. However, trial / sample, as the case may be, shall be permitted in cases where trial / sample are allowed as per approved and published procurement policy of the Buyers' controlling Ministry / Department / State / Public Sector Enterprises Headquarters. If there is any violation of trial / sample clause with regard to approved policy of the Buyers' Ministry / Department / State / Public Sector Enterprises Headquarters, then this is to be determined and redressed by the concerned Buyer Organisation only.
8. Seeking experience from specific organization / department / institute only or from foreign / export experience.
9. Creating bid for items from incorrect categories.
10. Reference of conditions published on any external site or reference to external documents/clauses.
11. Asking for any Tender fee / Bid Participation fee, as the case may be.
12. Buyer added ATC Clauses which are in contravention of clauses defined in bid detail section, including specifications, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by the applicable GeM GTC.
13. Any ATC clause in contravention with GeM GTC Clause 4 (xiii) (h) will be invalid. In case of multiple L1 bidders against a service bid, the buyer shall place the Contract by selection of a bidder amongst the L-1 bidders through a Random Algorithm executed by GeM system.
14. In a category based bid, adding additional items, through buyer added, additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogues or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

All GeM Sellers/Service Providers shall ensure full compliance with all applicable labour laws, including the provisions, rules, schemes and guidelines under the four Labour Codes i.e. the Code on Wages, 2019; the Industrial Relations Code, 2020; the Occupational Safety, Health and Working Conditions Code, 2020; and the Code on Social Security, 2020 as and when notified and brought into force by the Government of India.

For all provisions of the Labour Codes that are pending operationalisation through rules, schemes or notifications, the corresponding provisions of the pre-existing labour enactments (such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972, etc. and relevant State Rules) shall continue to remain applicable.

The Seller/ Service Providers shall, therefore, be responsible for ensuring compliance under:

- **All notified and enforceable provisions of the new Labour Codes as mentioned hereinabove; and**
- **All operative provisions of the erstwhile Labour Laws until their complete substitution.**

All obligations relating to wages, social security, safety, working conditions, industrial relations etc. and any other statutory requirements shall be strictly met by the Seller/ Service Provider. Any non-compliance shall constitute a breach of the contract and shall entitle the Buyer to take appropriate action in accordance with the contract and applicable law.

This Bid is governed by the General Terms and Conditions, conditions stipulated in Bid and Service Level Agreement specific to the Service, as the case may be, as provided in the Marketplace.

However, in case of Service, if any condition specified in General Terms and Conditions is contradicted by the conditions stipulated in Service Level Agreement specific to said Service, then it will over-ride the conditions in the General Terms and Conditions.

यह बिड सामान्य शर्तों के अंतर्गत भी शासित है /This Bid is also governed by the General Terms and Conditions.

जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा। In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---धन्यवाद/Thank You---