

बिड दस्तावेज़ / Bid Document

बिड विवरण / Bid Details	
बिड बंद होने की तारीख/समय / Bid End Date/Time	30-09-2026 11:00:00
बिड खुलने की तारीख/समय / Bid Opening Date/Time	01-10-2026 11:00:00
बिड पेशकश वैधता (बंद होने की तारीख से) / Bid Offer Validity (From End Date)	180 (Days)
मंत्रालय/राज्य का नाम / Ministry/State Name	Haryana
विभाग का नाम / Department Name	Irrigation Department Haryana
संगठन का नाम / Organisation Name	N/a
कार्यालय का नाम / Office Name	Irrigation & Water Resources Department Haryana, Panchkula
शिकायत निवारण के संपर्क विवरण / Contact details of Grievance redressal	HOD Email id : gm.irrigation@hry.nic.in Buyer Email id: pardeep.470@hid.gov.in
कुल मात्रा / Total Quantity	1
वस्तु श्रेणी / Item Category	Diesel Power Generator (V2) (Q2)
बिडर का न्यूनतम औसत वार्षिक टर्नओवर (3 वर्षों का) / Minimum Average Annual Turnover of the bidder (For 3 Years)	6.8 Lakh (s)
मूल उपकरण निर्माता का औसत टर्नओवर (गत 3 वर्षों का) / OEM Average Turnover (Last 3 Years)	7 Lakh (s)
उन्हीं/समान सेवा के लिए अपेक्षित विगत अनुभव के वर्ष / Years of Past Experience Required for same/similar service	2 Year (s)
टर्नओवर पात्रता मानदंड / Turnover eligibility criteria	To be verified by the buyer at the time of technical evaluation
एमएसएमई के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है / MSE Relaxation for Years of Experience and Turnover	No
स्टार्टअप के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है / Startup Relaxation for Years of Experience and Turnover	No

बिड विवरण/Bid Details	
विक्रेता से मांगे गए दस्तावेज़/Document required from seller	Experience Criteria,Past Performance,Bidder Turnover,Certificate (Requested in ATC),OEM Authorization Certificate,OEM Annual Turnover,Additional Doc 1 (Requested in ATC),Compliance of BoQ specification and supporting document *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
क्या आप निविदाकारों द्वारा अपलोड किए गए दस्तावेज़ों को निविदा में भाग लेने वाले सभी निविदाकारों को दिखाना चाहते हैं? संदर्भ मेनू है/Do you want to show documents uploaded by bidders to all bidders participated in bid?	Yes (Documents submitted as part of a clarification or representation during the tender/bid process will also be displayed to other participated bidders after log in)
बिड लगाने की समय सीमा स्वतः नहीं बढ़ाने के लिए आवश्यक बिड की संख्या। / Minimum number of bids required to disable automatic bid extension	2
दिनों की संख्या, जिनके लिए बिड लगाने की समय-सीमा बढ़ाई जाएगी। / Number of days for which Bid would be auto-extended	3
ऑटो एक्सटेंशन अधिकतम कितनी बार किया जाना है। / Number of Auto Extension count	2
विगत प्रदर्शन /Past Performance	30 %
बिड से रिवर्स नीलामी सक्रिय किया/Bid to RA enabled	Yes
रिवर्स नीलामी योग्यता नियम/RA Qualification Rule	H1-Highest Priced Bid Elimination
बिड का प्रकार/Type of Bid	Two Packet Bid
तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय /Time allowed for Technical Clarifications during technical evaluation	2 Days
निरीक्षण आवश्यक (सूचीबद्ध निरीक्षण प्राधिकरण /जेम के साथ पूर्व पंजीकृत एजेंसियों द्वारा)/Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
अनुमानित बिड मूल्य / Estimated Bid Value	1360000
Payment Timelines	Payments shall be made to the Seller within 45 days of issue consignee receipt-cum-acceptance certificate (CRAC) and on-line submission of bills (This is in supersession of 10 days time as provided in clause 12 of GeM GTC)
मूल्यांकन पद्धति/Evaluation Method	Total value wise evaluation
मध्यस्थता खंड/Arbitration Clause	No
सुलह खंड/Mediation Clause	No

ईएमडी विवरण/EMD Detail

एडवाइजरी बैंक/Advisory Bank	State Bank of India
ईएमडी राशि/EMD Amount	27200

ईपीबीजी विवरण /ePBG Detail

एडवाइजरी बैंक/Advisory Bank	State Bank of India
ईपीबीजी प्रतिशत (%) /ePBG Percentage(%)	5.00
ईपीबीजी की आवश्यक अवधि (माह) /Duration of ePBG required (Months).	12

(a). जेम की शर्तों के अनुसार ईएमडी छूट के इच्छुक बिडर को संबंधित केटेगरी के लिए बिड के साथ वैध समर्थित दस्तावेज प्रस्तुत करने हैं। एमएसई केटेगरी के अंतर्गत केवल वस्तुओं के लिए विनिर्माता तथा सेवाओं के लिए सेवा प्रदाता ईएमडी से छूट के पात्र हैं। व्यापारियों को इस नीति के दायरे से बाहर रखा गया है।/EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy.

(b).ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए। / EMD & Performance security should be in favour of Beneficiary, wherever it is applicable.

(c).ईएमडी और संपादन जमानत राशि लाभार्थी के पक्ष में होनी चाहिए। / Earnest Money Deposit (EMD) shall also be accepted by the buyer in the form of a surety bond.

लाभार्थी /Beneficiary :

Executive Engineer
Procurement and Disposal Division Panchkula Haryana
(Executive Engineer)

बोली विभाजन लागू नहीं किया गया/ Bid splitting not applied.

एमएसई खरीद वरीयता/MSE Purchase Preference

एमएसई खरीद वरीयता/MSE Purchase Preference	No
---	----

एमआईआई खरीद वरीयता/MII Purchase Preference

एमआईआई खरीद वरीयता/MII Purchase Preference	No
--	----

1. The minimum average annual financial turnover of the bidder during the last three years, ending on 31st March of the previous financial year, should be as indicated above in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution or incorporation of the bidder is less than 3-year-old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.

2. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM of the product offered in the bid {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU for number of Financial years as indicated above in the bid document before the bid opening date. Copies of relevant contracts and delivery acceptance certificates like CRAC to be submitted along with bid in support of having supplied some quantity during each of the

Financial year. In case of bunch bids, the category of primary product having highest value should meet this criterion.

3. OEM Turn Over Criteria: The minimum average annual financial turnover of the OEM of the offered product during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the OEM is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.

4. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

5. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 30% of bid quantity, in at least one of the last three Financial years before the bid opening date to any Central / State Govt Organization / PSU. Copies of relevant contracts (proving supply of cumulative order quantity in any one financial year) to be submitted along with bid in support of quantity supplied in the relevant Financial year. In case of bunch bids, the category related to primary product having highest bid value should meet this criterion.

6. Reverse Auction would be conducted amongst all the technically qualified bidders except the Highest quoting bidder. The technically qualified Highest Quoting bidder will not be allowed to participate in RA. However, H-1 will also be allowed to participate in RA in following cases:

- i. If number of technically qualified bidders are only 2 or 3.
- ii. If Buyer has chosen to split the bid amongst N sellers, and H1 bid is coming within N.
- iii. In case Primary product of only one OEM is left in contention for participation in RA on elimination of H-1.
- iv. If L-1 is non-MSE and H-1 is eligible MSE and H-1 price is coming within price band of 15% of Non-MSE L-1
- v. If L-1 is non-MII and H-1 is eligible MII and H-1 price is coming within price band of 20% of Non-MII L-1

Diesel Power Generator (V2) (1 pieces)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Installation Configuration	Installation Type	Skid Mounted, Trailer Mounted (Mobile)
Performance Parameters	Nominal Rated Capacity (in KVA)	125.0
	Number of Phases	Three Phase
Engine	Type of Engine Cooling	Liquid Cooled
Alternator	Alternator Voltage Rating (in volts)	415.0 (Volt)
Control Panel	Type of Control Panel	Manual Control Panel, AMF (Automatic Mains Failure) Control Panel Or higher

Additional Specification Parameters - Diesel Power Generator (V2) (1 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
1. Nominal rated capacity 2. No. of phase 3. Capacity of Engine (cc) 4. Type of engine cooling 5. No. of Cylinders 6. Salient features of engine 7. Alternator voltage rating 8. Rating of AC Generator (KVA)	1. 125 KVA 2. Three phase 3. Engine capacity suitable for achieving 125 kVA Prime rating, as per OEM standard design. 4. Liquid cooled 5. As per OEM standard design suitable for the specified 125 kVA rating. 6. CRDI fuel system of equivalent latest technology 7. 415 volt 8. 125
9. Power factor of AC Generator 10. Control Panel 11. Control panel location 12. Display meters in the control panel 13. Conformity to Indian standard (for alternator) 14. Cable Requirement	9. 0.8 lagging 10. Integrated Manual Control Panel with feature of Auto Start and Auto Stop subject to (Auto-Changeover in Customer's Scope) 11. Outside the Canopy 12. Voltmeter, ammeter, frequency meter, power factor meter, multifunctional digital display meter 13. Alternator shall conform to the latest applicable BIS/IS and relevant IEC standards, as amended from time to time 14. Suitable size/length cable as per site requirements
15. Emission norm 16. Enclosure features 17. Approved brands in Department 18. Power Generator Installation configuration as per CPWD General Specifications for Electrical works - part-VII DG Set 19. Required Experience	15. CPCB-IV+/ latest applicable standards. 16. Acoustic Enclosure with residential exhaust silencer, AVM Pads fitted on Base Frame 17. Tata, Mahindra Ashok Leyland Kirloskar (Koel Green), Cummines 18. DG set shall be supplied in fixed, skid-mounted/transportable or trailer-mounted/mobile configuration, as per requirement of the consignee and site conditions. 19. Atleast 30% of bid value in last 2 Financial Years (Experience of Authorized bidder or OEM both shall be considered.)
1. Nominal rated capacity 2. No. of phase 3. Capacity of Engine (cc) 4. Type of engine cooling 5. No. of Cylinders 6. Salient features of engine 7. Alternator voltage rating 8. Rating of AC Generator (KVA)	1. 125 KVA 2. Three phase 3. Engine capacity suitable for achieving 125 kVA Prime rating, as per OEM standard design. 4. Liquid cooled 5. As per OEM standard design suitable for the specified 125 kVA rating. 6. CRDI fuel system of equivalent latest technology 7. 415 volt 8. 125
9. Power factor of AC Generator 10. Control Panel 11. Control panel location 12. Display meters in the control panel 13. Conformity to Indian standard (for alternator) 14. Cable Requirement	9. 0.8 lagging 10. Integrated Manual Control Panel with feature of Auto Start and Auto Stop subject to (Auto-Changeover in Customer's Scope) 11. Outside the Canopy 12. Voltmeter, ammeter, frequency meter, power factor meter, multifunctional digital display meter 13. Alternator shall conform to the latest applicable BIS/IS and relevant IEC standards, as amended from time to time 14. Suitable size/length cable as per site requirements
15. Emission norm 16. Enclosure features 17. Approved brands in Department 18. Power Generator Installation configuration as per CPWD General Specifications for Electrical works - part-VII DG Set 19. Required Experience	15. CPCB-IV+/ latest applicable standards. 16. Acoustic Enclosure with residential exhaust silencer, AVM Pads fitted on Base Frame 17. Tata, Mahindra Ashok Leyland Kirloskar (Koel Green), Cummines 18. DG set shall be supplied in fixed, skid-mounted/transportable or trailer-mounted/mobile configuration, as per requirement of the consignee and site conditions. 19. Atleast 30% of bid value in last 2 Financial Years (Experience of Authorized bidder or OEM both shall be considered.)

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Pardeep Kumar	134109, Executive Engineer Procurement and Disposal Division Panchkula	1	30

Special terms and conditions-Version:1 effective from 10-06-2026 for category Diesel Power Generator (V2)

1. In addition to the General Terms and Conditions of the GeM, the following Special Terms and Conditions shall be applicable for Diesel Power Generator/DG Set:

1. For Trailer-Mounted DG Sets: The standard scope of supply includes installation, commissioning, and testing for all types of purchases.

2. For Skid Mounted DG Sets: The standard scope of supply includes commissioning and testing only and does not include installation for marketplace (Direct/L1) purchases.

3. General Technical Requirements:

a) DG Set shall be complete with Diesel Engine, Alternator and AMF/MANUAL Control Panel fitted in/along with Acoustic Enclosure. Diesel engine and alternator shall be closely coupled or provided with flexible coupling and mounted on a base plate of robust construction.

b) Control Panel (Manual / AMF), where applicable, shall be equipped with suitable Voltmeter, Ammeter, Frequency meter, power factor meter (these items can be alternatively supplied in one multifunctional digital display meter), battery charger where battery is used, indicators, various switches and cutout / MCB / MCCB / Contactor / Circuit breaker of all appropriate rating and accuracy class as per trade practice for better

c) Automatic Mains Failure (AMF) control panel, where applicable, shall be able to start up the DG set and transfer the load onto the DG set on mains failure without requiring any human intervention. Similarly, on restoration of mains supply, it shall be able to transfer the load to mains supply and switch off the DG set automatically.

d) Acoustic Enclosure, where applicable, shall be made of Pre-treated and Powder coated CRCA Sheet.

e) Standard set of tools consisting of a set of 3 spanners, one screwdriver, one standard plier and one nose plier of appropriate size shall be provided to the consignees along with DG

f) Anti-Vibration mountings for complete DG set in case of flexible coupling and for turbo charged engine and alternator in case of direct coupling shall be supplied.

g) Fuel tank capacity suitable for minimum 8 hours continuous running of the power generator at full load.

h) Engine should be capable of delivering an output of 10% in excess of the rated kVA for a period of one hour in any continuous 12-hour running period.

i) DG sets shall meet the requirements of Environmental (Protection) Rules 1986 as laid down by Min. of Environment & Forests read with GSR 371 (E) dated 17.5.2002, GSR 520(E) dated 1.7.2003, No.448 (E) dated 12.07.2004, GSR 771(E) dated 11.12.2013, GSR 232(E) dated 31.03.2014, Gazette Notification No.167 dated 31.03.2014 and Gazette Notification No. 578 dated 11.11. 2014. in respect of noise and emission norms. The latest amendments to the above GSRs shall be applicable as and when amended by the Ministry of Environment and Forests.

क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें/Buyer Added Bid Specific Terms and Conditions

1. Generic

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity up to 25% of the contracted quantity during the currency of the contract at the contract rates. The delivery period of quantity shall commence from the last date of original delivery order and in case where option clause is exercised during the extended delivery period the additional time shall commence from the last date of extended delivery period. The additional delivery time shall be $(\text{Increased quantity} \div \text{Original quantity}) \times \text{Original delivery period (in days)}$, subject to minimum of 30 days. If the original delivery period is less than 30 days, the additional time equals the original delivery period. The Purchaser may extend this calculated delivery duration up to the original delivery period while exercising the option clause. Bidders must comply with these terms.

2. Generic

Actual delivery (and Installation & Commissioning (if covered in scope of supply)) is to be done at following address

Sub Divisional Officer
Israna Water Services
Sub Division PWD
Irrigation and Water Resources Haryana
Panipat, Haryana

3. **Scope of Supply**

Scope of supply (Bid price to include all cost components) : Supply Installation Testing and Commissioning of Goods

4. **Inspection**

Pre-dispatch inspection at Seller premises (Fee/Charges to be borne by the BUYER): Before dispatch the goods will be inspected by Buyer / Consignee or their Authorized Representative or by Nominated External Inspection Agency (independently or jointly with Buyer or Consignee as decided by the Buyer) at Seller premises (or at designated place for inspection as declared / communicated by the seller) for their compliance to the contract specifications. Fee/Charges taken by the External inspection Agency and any external laboratories testing charges shall be borne by the Buyer. For in-house testing, the Sellers will provide necessary facilities free of cost. Seller shall notify the Buyer through e-mail about readiness of goods for pre-dispatch inspection and Buyer will notify the Seller about the Authorized Representative/ Nominated External Inspection Agency and the date for testing. The goods would be dispatched to consignee only after clearance pre-dispatch inspection. Consignee's right of rejection as per GTC in respect of the goods finally received at h location shall in no way be limited or waived by reason of the goods having previously been inspected, tested and passed by Buyer/ Consignee or its Nominated External Inspection Agency prior to the goods' shipment. While bidding, the sellers should take into account 7 days for inspection from the date of email offering the goods for inspection. Any delay in inspection beyond 7 days shall be on the part of the buyer and shall be regularised without Liquidated Damages.

When there is requirement of submission the advance sample, the seller shall inform the buyer promptly through emails about the date of submission of sample to the buyer nominated Inspection agency.

5. **Turnover**

OEM Turn Over Criteria: The minimum average annual financial turnover of the OEM of the offered product during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the OEM is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria. In case of bunch bids, the OEM of CATEGORY RELATED TO primary product having highest bid value should meet this criterion.

6. **Buyer Added Bid Specific ATC**

Buyer uploaded ATC document [Click here to view the file.](#)

7. **Buyer Added Bid Specific ATC**

Buyer Added text based ATC clauses

Additional Terms & Conditions of supply, Erection and commissioning of one No. DG Set nominal rated capacity 125 KVA as under given below:-

1. Nominal rated capacity	1. 125 KVA
2. No. of phase	2. Three phase
3. Capacity of Engine (cc)	3. Engine capacity suitable for achieving 125 kVA Prime rating, as per OEM standard design.
4. Type of engine cooling	4. Liquid cooled
5. No. of Cylinders	5. As per OEM standard design suitable for the specified 125 kVA rating.
6. Salient features of engine	6. CRDI fuel system or equivalent latest technology
7. Alternator voltage rating	7. 415 volt
8. Rating of AC Generator (KVA)	8. 125
9. Power factor of AC Generator	9. 0.8 lagging
10. Control Panel	10. Integrated Manual Control Panel with feature of Auto Start and Auto Stop subject to (Auto-Chan over in Customer's Scope)
11. Control panel location	11. Outside the Canopy
12. Display meters in the control panel	12. Voltmeter, ammeter, frequency meter, power factor meter, multifunctional digital display meter
13. Conformity to Indian standard (for alternator)	13. Alternator shall conform to the latest applicable BIS/IS and relevant IEC standards, as amended from time to time
14. Cable Requirement	14. Suitable size/length cable as per site requirements
15. Emission norm	15. CPCB-IV+/ latest applicable standards.
16. Enclosure features	16. Acoustic Enclosure with residential exhaust silencer, AVM Pads fitted on Base Frame
17. Approved brands in Department	17. Tata, Mahindra, Ashok Leyland, Kirloskar (Koe Green), Cummines
18. Power Generator Installation configuration as per CPWD General Specifications for Electrical works - part-VII DG Set	18. DG set shall be supplied in fixed, skid-mounted transportable or trailer-mounted/mobile configuration, as per requirement of the consignee and its conditions.
19. Required Experience	19. Atleast 30% of bid value in last 2 Financial Year (Experience of Authorized bidder or OEM both shall be considered.)

अस्वीकरण/Disclaimer

The Additional Terms and Conditions (ATC) have been incorporated by the Buyer after approval of their Competent Authority. The Buyer ,is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any restriction arising in the bidding process due to these ATCs and including the modification of technical specifications and / or terms and conditions governing the bid.All representations / grievances pertaining to the ATC clauses shall be raised with the buyer organization directly and not with GeM.If any of the clause(s) is/are incorporated by the Buyer regarding the following, the bid & resultant contract shall be treated

as null & void. Further, GeM reserves the right, at its sole discretion, to cancel the bid forthwith, without issuance of any prior notice or intimation :-

1. Publishing Custom / BOQ bids for items for which regular GeM categories are available (unless such Custom / BOQ item is bunched with the major regular product Category Item).
2. Mandating procurement of / from specific Brand / Make / Model / Manufacturer / Dealer except in case of Sing Bid / Proprietary Article Certificate (PAC) Buying.
3. Inclusion of disqualification criteria related to suspension of seller / service provider, where such suspension period has already expired.
4. Mandating submission of documents (other than EMD and signed Integrity Pact - which can be submitted with 5 days of bid opening) in physical form as a pre-requisite to qualify bidders.
5. Publishing bids on GeM for procurement of works.
6. Procurement of Goods by creating a Service bid on GeM & vice-versa.
7. Seeking sample with bid or approval of samples during bid evaluation process. However, trial / sample, as the case may be, shall be permitted in cases where trial / sample are allowed as per approved and published procurement policy of the Buyers' controlling Ministry / Department / State / Public Sector Enterprises Headquarters. If there is any violation of trial / sample clause with regard to approved policy of the Buyers' Ministry / Department / State / Public Sector Enterprises Headquarters, then this is to be determined and redressed by the concerned Buyer Organisation only.
8. Seeking experience from specific organization / department / institute only or from foreign / export experience.
9. Creating bid for items from incorrect categories.
10. Reference of conditions published on any external site or reference to external documents/clauses.
11. Asking for any Tender fee / Bid Participation fee, as the case may be.
12. Buyer added ATC Clauses which are in contravention of clauses defined in bid detail section, including specifications, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by the applicable GeM GTC.
13. Any ATC clause in contravention with GeM GTC Clause 4 (xiii) (h) will be invalid. In case of multiple L1 bidders against a service bid, the buyer shall place the Contract by selection of a bidder amongst the L-1 bidders through a Random Algorithm executed by GeM system.
14. In a category based bid, adding additional items, through buyer added, additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogues or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

All GeM Sellers/Service Providers shall ensure full compliance with all applicable labour laws, including the provisions, rules, schemes and guidelines under the four Labour Codes i.e. the Code on Wages, 2019; the Industrial Relations Code, 2020; the Occupational Safety, Health and Working Conditions Code, 2020 and the Code on Social Security, 2020 as and when notified and brought into force by the Government of India.

For all provisions of the Labour Codes that are pending operationalisation through rules, schemes or notifications, the corresponding provisions of the pre-existing labour enactments (such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972, etc. and relevant State Rules) shall continue to remain applicable.

The Seller/ Service Providers shall, therefore, be responsible for ensuring compliance under:

- All notified and enforceable provisions of the new Labour Codes as mentioned hereinabove; and
- All operative provisions of the erstwhile Labour Laws until their complete substitution.

All obligations relating to wages, social security, safety, working conditions, industrial relations etc. and any other statutory requirements shall be strictly met by the Seller/ Service Provider. Any non-compliance shall constitute a breach of the contract and shall entitle the Buyer to take appropriate action in accordance with the contract and applicable law.

This Bid is governed by the General Terms and Conditions, conditions stipulated in Bid and Service Level Agreement specific to the Service, as the case may be, as provided in the Marketplace.

However, in case of Service, if any condition specified in General Terms and Conditions is contradicted by the conditions stipulated in Service Level Agreement specific to said Service, then it will over-ride the conditions in the General Terms and Conditions.

[यह बिड सामान्य शर्तों के अंतर्गत भी शासित है /This Bid is also governed by the General Terms and Conditions](#)

जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकार के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।/In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration or non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---धन्यवाद/Thank You---