बिड संख्या/Bid Number: GEM/2026/B/8249825
दिनांक /Dated: 06-11-2026

बिड दस्तावेज़ / Bid Document

बिड विवरण/Bid Details	
बिड बंद होने की तारीख/समय /Bid End Date/Time	16-11-2026 18:00:00
बिड खुलने की तारीख/समय /Bid Opening Date/Time	17-11-2026 18:00:00
बिड पेशकश वैधता (बंद होने की तारीख से)/Bid Offer Validity (From End Date)	60 (Days)
मंत्रालय/राज्य का नाम/Ministry/State Name	Uttar Pradesh
विभाग का नाम/Department Name	Urban Development Department Uttar Pradesh
संगठन का नाम/Organisation Name	N/a
कार्यालय का नाम/Office Name	Nagar Panchayat Mariahu Jaunpur
शिकायत निवारण के संपर्क विवरण/ Contact details of Grievance redressal	HOD Email id :eonpmadiyahuju-up@nic.in Buyer Email id: npmariahu@gmail.com
कुल मात्रा/Total Quantity	1
वस्तु श्रेणी /Item Category	High Mast Lighting Tower for large area with LED Flood Lighting System (Q3)
पिछले 3 वित्तीय वर्षों का बिडर का न्यूनतम औसत वार्षिक वित्तीय टर्नओवर/Minimum Average Annual Turnover of the bidder (For the last 3 Financial Years)	3 Lakh (s)
मूल उपकरण निर्माता का औसत टर्नओवर (गत 3 वर्षों का)/OEM Average Turnover (Last 3 Years)	3 Lakh (s)
टर्नओवर पात्रता मानदंड/Turnover eligibility criteria	To be verified by the buyer at the time of technical evaluation
वर्षों के अनुभव एवं टर्नओवर से एमएसई को छूट प्राप्त है / MSE Relaxation for Years Of Experience and Turnover	Yes | Partial | Experience - 0 year (s) | Turn over value - 0 (in lakhs)
स्टार्टअप के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है / Startup Relaxation for Years Of Experience and Turnover	Yes | Partial | Experience - 0 year (s) | Turn over value - 0 (in lakhs)
विक्रेता से मांगे गए दस्तावेज़/Document required from seller	Experience Criteria,Bidder Turnover,Certificate (Requested in ATC),OEM Authorization Certificate,OEM Annual Turnover,Additional Doc 1 (Requested in ATC) *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer

बिड विवरण/Bid Details	
क्या आप निविदाकारों द्वारा अपलोड किए गए दस्तावेज़ों को निविदा में भाग लेने वाले सभी निविदाकारों को दिखाना चाहते हैं? संदर्भ मेनू है/**Do you want to show documents uploaded by bidders to all bidders participated in bid?**	Yes (Documents submitted as part of a clarification or representation during the tender/bid process will also be displayed to other participated bidders after log in)
बिड लगाने की समय सीमा स्वतः नहीं बढ़ाने के लिए आवश्यक बिड की संख्या। / **Minimum number of bids required to disable automatic bid extension**	3
दिनों की संख्या, जिनके लिए बिड लगाने की समय-सीमा बढ़ाई जाएगी। / **Number of days for which Bid would be auto-extended**	3
ऑटो एक्सटेंशन अधिकतम कितनी बार किया जाना है। / **Number of Auto Extension count**	2
बिड से रिवर्स नीलामी सक्रिय किया/**Bid to RA enabled**	No
बिड का प्रकार/**Type of Bid**	Two Packet Bid
तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय /**Time allowed for Technical Clarifications during technical evaluation**	2 Days
निरीक्षण आवश्यक (सूचीबद्ध निरीक्षण प्राधिकरण /जेम के साथ पूर्व पंजीकृत एजेंसियों द्वारा)/**Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)**	No
अनुमानित बिड मूल्य / **Estimated Bid Value**	649096
Payment Timelines	Payments shall be made to the Seller within **45** days of issue of consignee receipt-cum-acceptance certificate (CRAC) and on-line submission of bills (This is in supersession of 10 days time as provided in clause 12 of GeM GTC)
मूल्यांकन पद्धति/**Evaluation Method**	Total value wise evaluation
मध्यस्थता खंड/**Arbitration Clause**	No
सुलह खंड/**Mediation Clause**	No

ईएमडी विवरण/EMD Detail

एडवाईजरी बैंक/Advisory Bank	State Bank of India
ईएमडी राशि/EMD Amount	32454

ईपीबीजी विवरण /ePBG Detail

आवश्यकता/Required	No

(a). जेम की शर्तों के अनुसार ईएमडी छूट के इच्छुक बिडर को संबंधित केटेगरी के लिए बिड के साथ वैध समर्थित दस्तावेज़ प्रस्तुत करने है। एमएसई केटेगरी के अंतर्गत केवल वस्तुओं के लिए विनिर्माता तथा सेवाओं के लिए सेवा प्रदाता ईएमडी से छूट के पात्र हैं। व्यापारियों को इस नीति के दायरे से बाहर रखा गया है।/EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy.

(b).ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए। / EMD & Performance security should be in favour of Beneficiary, wherever it is applicable.

(c).ईएमडी और संपादन जमानत राशि लाभार्थी के पक्ष में होनी चाहिए। / Earnest Money Deposit (EMD) shall also be accepted by the buyer in the form of a surety bond.

लाभार्थी /Beneficiary :

Executive officer
Nagar Panchayat Mariahu Jaunpur, Urban Development Department Uttar Pradesh, N/A,
(Executive Officer Nagar Panchayat Mariahu)

बोली विभाजन लागू नहीं किया गया/ Bid splitting not applied.

एमएसई खरीद वरीयता/MSE Purchase Preference

एमएसई खरीद वरीयता/MSE Purchase Preference	No

एमआईआई खरीद वरीयता/MII Purchase Preference

एमआईआई खरीद वरीयता/MII Purchase Preference	No

1. If the bidder is a Micro or Small Enterprise as per latest orders issued by Ministry of MSME, the bidder shall be relaxed from the eligibility criteria of "Experience Criteria" as defined above subject to meeting of quality and technical specifications. The bidder seeking Relaxation from Experience Criteria, shall upload the supporting documents to prove his eligibility for Relaxation.
2. If the bidder is a Micro or Small Enterprise (MSE) as per latest orders issued by Ministry of MSME, the bidder shall be relaxed from the eligibility criteria of "Bidder Turnover" as defined above subject to meeting of quality and technical specifications. If the bidder itself is MSE OEM of the offered products, it would be relaxed from the "OEM Average Turnover" criteria also subject to meeting of quality and technical specifications. The bidder seeking Relaxation from Turnover, shall upload the supporting documents to prove his eligibility for Relaxation.
3. If the bidder is a DPIIT registered Startup, the bidder shall be relaxed from the the eligibility criteria of "Experience Criteria" as defined above subject to their meeting of quality and technical specifications. The bidder seeking Relaxation from Experience Criteria, shall upload the supporting documents to prove his eligibility for Relaxation.
4. If the bidder is a DPIIT registered Startup, the bidder shall be relaxed from the the eligibility criteria of "Bidder Turnover" as defined above subject to their meeting of quality and technical specifications. If the bidder is DPIIT Registered OEM of the offered products, it would be relaxed from the "OEM Average Turnover" criteria also subject to meeting of quality and technical specifications. The bidder seeking Relaxation from Turnover shall upload the supporting documents to prove his eligibility for Relaxation.
5. The minimum average annual financial turnover of the bidder during the last three years, ending on 31st March of the previous financial year, should be as indicated above in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the bidder is less than 3-year-old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.
6. OEM Turn Over Criteria: The minimum average annual financial turnover of the OEM of the offered product during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a

certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the OEM is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.
7. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

High Mast Lighting Tower For Large Area With LED Flood Lighting System (1 pieces)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification]

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	**Height of High Mast Tower (in Meters)**	16
	Installation and commissioning (Installation and commissioning work at multiple locations shall follow as per the guidelines of State/Central Govt rules and regulations as applicable)	Yes. Including Civil work at site
	Onsite warranty (in Years)	5
High mast System	**No of sections**	2
	Effective length of each section (in m)	8.5
	Material construction: The mast shall be manufactured using special steel plates, conforming to	355 gradeasper BSEN10 025
	Bottom diameter (in mm) - Minimum	540
	Plate thickness for Middle (in mm) - Minimum	4
	Plate thickness for Bottom (in mm) - Minimum	5
	No of longitudinal welds / section (in Nos)	1
	Diameter of base plate (in mm) - Minimum	740
	Thickness of base plate (in mm) - Minimum	25
Wind Load	**Maximum Wind load**	50 m/sec

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Door Opening	**Size of opening and closing door at base compartment of high mast (in mm) - Minimum**	1200 x 250
Junction Box	**Ingress protection for Junction Box i.e. IP Class (as per IS/IEC:60529:2001 latest) Test Report from Central Government lab/NABL/ILAC accrediated lab and report shall furnish to buyer on demand**	IP 55
	No of core	4
	Cable category	FR
	Size of cable (in Sq mm)	2.5
	Conductor material shall be	Copper
Winch	**The winch shall have provision for manual operation in case of failure of the motor**	Yes
Stainless Steel Wire Rope	**The breaking load of each rope shall be at full load as per the relevant standard**	>/=2250Kg
Electrical System, Cable and Cable Connections	**No. of cores**	4
	Cable shall be	Armoured
	Conudctor material shall be	Aluminium
	Cable Category	C2
	Incoming power cable from feeder panel to base compartment of mast and cable shall conforming to	IS:7098 (Part 1):1988 latest
Feeder pillar Panel	**Feeder pillar panel for each mast**	Yes
	Feeder panel shall be suitable for	415 V, 3 phase, 4 wire, 50 Hz, AC
	The control panels shall be	Stand mounted
	Ingress protection for feeder pillar panel i.e IP Class (as per IS/IEC:60529:2001 latest).Test Report shall furnish from Central Government lab/NABL/ILAC accrediated lab to buyer on demand	IP 55
	It shall be fabricated out of	14 SWG CRCA sheet steel

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Thickness of sheet (in mm)	2
	The panels shall be given pre-treatment and powder coated and color shall be	Grey
	The stand shall be painted in	Black color
	Cable entry shall be at the	Bottom
	The panels shall have	knock outs of the required cable
	Laminated circuit diagram shall be pasted	inside of the door
	Feeder pillar shall have pad locking arrangement	Yes
	Earth terminal	12 mm dia. Bolts
	Panel shall have a sloping cover to avoid accumulation of dust	Yes
	Panel shall be provided with incoming & outgoing MCCB / MCB of appropriate rating and in desired quantity depending on total no of circuits in use	yes
	Timer for automatic ON & OFF of lights with pilot lamps shall be provided	Yes
	Bus bars material	Yes. Copper
	No of Cores	4
	Size of cable (in Sq.mm)	16
	Cable Shall be	Armoured
	The conductor material shall be	Aluminium
	cable category	C2
LED FLOOD LIGHT LUMINAIRE	**No. of Luminaires for each high mast lighting tower (in Nos)**	8
	LED Rating/System Wattage/Rated Power for each luminaire	200W
	Luminaire System Efficacy (Lumen/watt)	>/= 100 Lm/Watt
	Ingress Protection (IP Rating) as per IS:10322 (Part 1):1982 latest	IP66

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Mounting brackets (included)	Adjustable
	Input operating Voltage range and frequency	140 to 270 Volts AC at 50 Hz+/-2 Hz with auto cutt off at below 120V
	Rated voltage	415+/-10% V AC 50 Hz +/-5%
	Colour temperature	6000K (+/- 500K)
	Optic lense material (UV stabilised) (Write NA for without optic lense supply)	Poly carbonate lense
	Operating temperature range	-10 deg C to +50 deg C
	The luminaire shall be protected against surges and transients(Internal)	>/=4KV
	Number of electronic control gear per luminaire (power supplies)	1 No.
	Length of ISI marked three core wire (shall be provided along with supply of material)	100 cm

Additional Specification Parameters - High Mast Lighting Tower For Large Area With LED Flood Lighting System (1 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
200W LED FLOODLIGHT AAA	Supply and fixing of factory wired integral LED flood light luminaires with die cast aluminium housing built with driver set suitable for 200 Watt. Confirming to IP 66 protection complete in all respect.
25SQMM 3.5C AL ARMOURED XLPE CABLE	Supply & laying of 25 sq.Mm 3.5 core aluminium conducter pve insulated armoured served sheathed cables 1100volts grade at a depth of 750 mm below ground level over a chushion 05 75 mm thick sand all around and protected with brunt bricks on sides and top complete in all respects. (As per PWD 2024 Sch no. 20a.1.10)
HDPE PIPE	Supply and Laying of 40mm PVC HDPE pipe in which the Aluminium Conductor Cable shall be laid. (Nonschedule Item - As per Market Rate)
HIGHMAST FEEDER PILLAR	Supply and fixing of automatic street light cubical control panel painted with anticorrosive and acid proof paint H.R.C fuse insolating switch material complete in all respects . (As per PWD 2018 Schedule No.807 F
NAME STONE	Supply & Fixing of Name Stone. (As per Market Rate)

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Brajesh Mishra	222161,Mariahu, Mariahu, Jaunpur	1	60

Buyer added Bid Specific Additional Scope of Work

क्र.सं./S.No.	Document Title	Description	रिवर्स प्रभार के अनुसार जीएसटी/Applicable i.r.o. Items
1	ESTIMATE View	ESTIMATE AND ALL DETAIL OF WORK WITH SITE NAME	High Mast Lighting Tower For Large Area With LED Flood Lighting System(1)

The uploaded document only contains Buyer specific Additional Scope of Work and / or Drawings for the bid items added with due approval of Buyer's competent authority. Buyer has certified that these additional scope and drawings are generalized and would not lead to any restrictive bidding.

क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें/Buyer Added Bid Specific Terms and Conditions

1. **Generic**

   OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity up to 25% of the contracted quantity during the currency of the contract at the contracted rates. The delivery period of quantity shall commence from the last date of original delivery order and in cases where option clause is exercised during the extended delivery period the additional time shall commence from the last date of extended delivery period. The additional delivery time shall be (Increased quantity ÷ Original quantity) × Original delivery period (in days), subject to minimum of 30 days. If the original delivery period is less than 30 days, the additional time equals the original delivery period. The Purchaser may extend this calculated delivery duration up to the original delivery period while exercising the option clause. Bidders must comply with these terms.

2. **Scope of Supply**

   Scope of supply (Bid price to include all cost components) : Supply Installation Testing and Commissioning of Goods

3. **Generic**

   Bidder financial standing: The bidder should not be under liquidation, court receivership or similar proceedings, should not be bankrupt. Bidder to upload undertaking to this effect with bid.

4. **Generic**

   Bidders are advised to check applicable GST on their own before quoting. Buyer will not take any responsibility in this regards. GST reimbursement will be as per actuals or as per applicable rates (whichever is lower), subject to the maximum of quoted GST %.

5. **Turnover**

   Bidder Turn Over Criteria: The minimum average annual financial turnover of the bidder during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid

document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the bidder is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.

6. **Turnover**

   OEM Turn Over Criteria: The minimum average annual financial turnover of the OEM of the offered product during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the OEM is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria. In case of bunch bids, the OEM of CATEGORY RELATED TO primary product having highest bid value should meet this criterion.

7. **Certificates**

   ISO 9001: The bidder or the OEM of the offered products must have ISO 9001 certification.

8. **Past Project Experience**

   The Bidder / OEM {themselves or through reseller(s)}, should have executed project for supply and installation / commissioning of same or similar Category Products during preceding 3 financial years (i.e. current year and three previous financial years) as on opening of bid, as per following criteria:

   (i) Single order of at least 35% of estimated bid value; or
   (ii) Two orders of at least 20% each of estimated bid value; or
   (iii) Three orders of at least 15% each of estimated bid value.
   Satisfactory Performance certificate issued by respective Buyer Organization for the above Orders should be uploaded with bid. In case of bunch bids, the Category related to primary product having highest bid value should meet this criterion

9. **Buyer Added Bid Specific ATC**

   Buyer Added text based ATC clauses

   Term & Condition:

   1. As India per to Govt. of India program(MEITY), The product manufacturer must have manufacturing facili ty in INDIA to promote “MAKE IN INDIA” and declaration certificate for the same.

   2. Manufacturer/OEM/Bidder should submit LM79 test report, TDS report and IP65/ IP66/IP67 Protection Re port.

   3. Manufacturer/OEM/Bidder should have BIS registration certificate and each LED light should be BIS Certified.

   4. As per Govt. Act., Fittings should have CRS No.(Compulsory Registration Scheme) from BIS as per IS sta ndard.

   5. Bidder shall be authorized by the OEM & certificate for participating in the tender is mandatory to been closed with the bid documents. Bid Specific Authorisation is mandatory.

   6. Manufacturer/OEM/Bidder must submit 5 years warranty and Guarantee certificate on Notarized Stamp paper of 100/-Rs.

   7. Manufacturer/OEM/Bidder have to submit one sample of the 200W LED fixture before opening the tender .

   8. Manufacturer/OEM/Bidder should upload GST, PAN, CHARACTER CERTIFICATE, ADHAR, SOLVENCY CERTI FICATE, LABOUR CERTIFICATE and MSME CERTIFICATE etc.

9. Manufacturer/OEM/Bidder should upload Non-Back listed Notarized Stamp of 100/-Rs.

10. CA Certified turnover certificate for last 3 financial years, or Audited balance sheet of last 3 years to be uploaded mention UDIN number with minimum 75%of bid value not more than 6 month.

11. CA Certified Net worth Certificate to be Uploaded.

12. ITR documents of last 3 Years to be uploaded.

13. Service centre details and Flood Light(LED) Sample Should be Submitted along with hard copy of EMD i n the Nagar Panchayat Mariahu Office.

14. Character certificate verified from DM of the District.

15. EMD 5% of the bid/tender value favoring Executive officer Nagar Panchayat Mariahu Office to the sub mitted along with hard copy submitted in the office during official time.

16. The Contractors/bidders must be authorized by the respective OEM to participate in the tender and the certificate must be enclosed with the bidder's documents.

17. ISO Certificate of OEM & Bidder both should be submitted with the bid.

18. The Bidder must provide authorization of Floodlight Lighting Manufacturer (OEM) and Highmast Manufa cturer (OEM) mentioning the Bid Numbers and Validity.

19. PWD Approval Certificate of OEM for Floodlight and Highmast needs to be uploaded. Only AAA Category of Streetlight is accepted.

20. Valid Haisiyat Praman Patr issued by DM or Solvency Certificate issued by Bank should be uploaded.

21. NABL Certificate of OEM to be uploaded.

22. OEM should have In-house Manufacturing Unit for Drivers. In case the drivers are being outsourced fro m some other company, then TDS, TTC Report of Driver, Service Centre Details, Warranty Certificate, ITR & Balance Sheet of the company manufacturing the Driver should also be uploaded.

23. Details of Technical Employees (Wireman & Supervisor) should be mentioned by the bidder on Bidder’ s Letter Head and the same should be uploaded with the bid.

24. Bidders are advised to refer to the Estimate containing all details of Work to be done attached in Additi onal Scope of Work, before participating. The work details mentioned in the same are to be done.

.

अस्वीकरण/Disclaimer

The Additional Terms and Conditions (ATC) have been incorporated by the Buyer after approval of their Competent Authority. The Buyer ,is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any restriction arising in the bidding process due to these ATCs and including the modification of technical specifications and / or terms and conditions governing the bid.All representations / grievances pertaining to the ATC clauses shall be raised with the buyer organization directly and not with GeM.If any of the clause(s) is/are incorporated by the Buyer regarding the following, the bid & resultant contract shall be treated as null & void. Further, GeM reserves the right, at its sole discretion, to cancel the bid forthwith, without issuance of any prior notice or intimation :-

1. Publishing Custom / BOQ bids for items for which regular GeM categories are available (unless such Custom / BOQ item is bunched with the major regular product Category Item).
2. Mandating procurement of / from specific Brand / Make / Model / Manufacturer / Dealer except in case of Single Bid / Proprietary Article Certificate (PAC) Buying.
3. Inclusion of disqualification criteria related to suspension of seller / service provider, where such suspension period has already expired.
4. Mandating submission of documents (other than EMD and signed Integrity Pact - which can be submitted within 5 days of bid opening) in physical form as a pre-requisite to qualify bidders.

5. Publishing bids on GeM for procurement of works.
6. Procurement of Goods by creating a Service bid on GeM & vice-versa.
7. Seeking sample with bid or approval of samples during bid evaluation process. However, trial / sample, as the case may be, shall be permitted in cases where trial / sample are allowed as per approved and published procurement policy of the Buyers' controlling Ministry / Department / State / Public Sector Enterprises Headquarters. If there is any violation of trial / sample clause with regard to approved policy of the Buyers' Ministry / Department / State / Public Sector Enterprises Headquarters, then this is to be determined and redressed by the concerned Buyer Organisation only.
8. Seeking experience from specific organization / department / institute only or from foreign / export experience.
9. Creating bid for items from incorrect categories.
10. Reference of conditions published on any external site or reference to external documents/clauses.
11. Asking for any Tender fee / Bid Participation fee, as the case may be.
12. Buyer added ATC Clauses which are in contravention of clauses defined in bid detail section, including specifications, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by the applicable GeM GTC.
13. Any ATC clause in contravention with GeM GTC Clause 4 (xiii) (h) will be invalid. In case of multiple L1 bidders against a service bid, the buyer shall place the Contract by selection of a bidder amongst the L-1 bidders through a Random Algorithm executed by GeM system.
14. In a category based bid, adding additional items, through buyer added, additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogues or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

All GeM Sellers/Service Providers shall ensure full compliance with all applicable labour laws, including the provisions, rules, schemes and guidelines under the four Labour Codes i.e. the Code on Wages, 2019; the Industrial Relations Code, 2020; the Occupational Safety, Health and Working Conditions Code, 2020; and the Code on Social Security, 2020 as and when notified and brought into force by the Government of India.

For all provisions of the Labour Codes that are pending operationalisation through rules, schemes or notifications, the corresponding provisions of the pre-existing labour enactments (such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972, etc. and relevant State Rules) shall continue to remain applicable.

The Seller/ Service Providers shall, therefore, be responsible for ensuring compliance under:

- **All notified and enforceable provisions of the new Labour Codes as mentioned hereinabove; and**
- **All operative provisions of the erstwhile Labour Laws until their complete substitution.**

All obligations relating to wages, social security, safety, working conditions, industrial relations etc. and any other statutory requirements shall be strictly met by the Seller/ Service Provider. Any non-compliance shall constitute a breach of the contract and shall entitle the Buyer to take appropriate action in accordance with the contract and applicable law.

This Bid is governed by the General Terms and Conditions, conditions stipulated in Bid and Service Level Agreement specific to the Service, as the case may be, as provided in the Marketplace.

However, in case of Service, if any condition specified in General Terms and Conditions is contradicted by the conditions stipulated in Service Level Agreement specific to said Service, then it will over-ride the conditions in the General Terms and Conditions.

यह बिड सामान्य शर्तों के अंतर्गत भी शासित है /This Bid is also governed by the General Terms and Conditions

जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो।बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।/In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---धन्यवाद/Thank You---